



DFD Architecture, LLC
PO Box 182, Spring Lake, MI 49456

dfdarchitecture@gmail.com
616 821 0936

Project Number 001-2017
August 27, 2018

Contract Documents
Masjid Sunnah Renovation
2312 South Division Avenue
Grand Rapids, MI 49507

Addenda No. 1A

NOTICE TO ALL PROSPECTIVE BIDDERS

This addenda is hereby made part of the Contract Documents

Sheet A111, Replace Fixtures J with Fixtures F on the outside of the building.

Sheet M200, Furnace F-2 is located in room 104, North Basement 2 (Upper half of plan)
CU-1 and CU-2 are located on the roof.

Sheet E104 ONE LINE DIAGRAM should read: PANEL A - **200 A**, 120 - 240 V, 1Phase/3w
Remove PANEL H

Sheet E105, Remove PANEL H, Move any CKT from PANEL H to PANEL A
PANEL A should read, CKT 29, 31, 33 - RECEPTACLES ROOM 8
CKT 18 - RECEPTACLE ROOM 7

Sheet E300, On upper half of plan, North Basement, add an additional set of lights (2 - A Fixtures and 1
AEM Fixture) and connect to the same switch. An additional wall was added, see Sheet A100.

Sheet E300, On lower half of plan, South Basement, add an additional set of lights (2 - A Fixtures and 1
AEM Fixture) and connect to the same switch. An additional wall was added, see Sheet A100.

Sheet E301, Replace Fixture H in upper left Room 7, Vestibule, with Fixture E.
Over the 3 front entrances add Fixtures F.

End of Addenda No. 1A